



OFFICIAL LISTING

NSF certifies that the products appearing on this Listing conform to the requirements of
NSF/ANSI/CAN 61 - Drinking Water System Components - Health Effects

This is the Official Listing recorded on August 12, 2019.

Weicon GmbH & Co. KG
Konigsberger Str. 255
DE-48157 Munster
Germany
49 251 93 22 0

Facility: # 1 USA

Joining and Sealing Materials

Trade Designation	Size	Water Contact Temp	Water Contact Material
Patching Materials			
Repair Stick Plastic	[1]	C. HOT	EPOXY
Sealants			
Repair Stick Copper	[1]	C. HOT	EPOXY
Repair Stick Multi Purpose ^[G]	[1]	C. HOT	EPOXY
Repair Stick Stainless Steel ^[G]	[1]	C. HOT	EPOXY
Repair Stick Steel ^[G]	[1]	C. HOT	EPOXY

[1] The exposed surface area of each sealant in a household distribution system shall not exceed 1.3 sq. cm/L or .2 sq. in./L

[G] Product is Certified to NSF/ANSI 372 and conforms with the lead content requirements for "lead free" plumbing as defined by California, Vermont, Maryland, and Louisiana state laws and the U.S. Safe Drinking Water Act.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF.

1 of 1