



Mr Norman Otto
 Weicon GmbH & Co KG
 Konigsberger Str 255
 48157 Muenster
 GERMANY

AGA notification of action(s) following Product Verification Audit

Certificate Holder	Weicon GmbH & Co KG
Manufacturer	Weicon GmbH & Co KG
Certificate No.	6915
Specification issue	03
Type of Component	Jointing Materials and Compounds - Jointing Compounds
Product Description	Weiconlock Anaerobic Thread Sealant Model: AN305-72
Model No.	305-72
Serial No.	9117201194013
Certification to Standard(s)	AS 4623 / 2008 / Jointing compounds and materials for use in gas pipe joints / 30 Jun 2008
Name of Auditor	Jim Burns
Date of Audit	25 Nov 2019
Audit conducted at	AGA Office. North Parramatta, NSW.

Audit summary

Non-conformance(s) / observation(s) are noted for items under review at this Audit. These details appear in the Audit Findings (page 2 of this document) and require your attention by the due date(s).

Note:

- *If you cannot meet the time frame indicated (Due Date), please formally respond in writing and advise of your intentions*
- *The Audit process is both random and selective and it is based on a limited assessment of a representative sample or samples of a Production Unit and on relevant quality assurance measures*
- *We welcome and encourage customer feedback about the audit process or any other certification issue*
- *Under the requirements of the AGA Rules Governing, it's the Certificate Holders' responsibility to:*
 - *ensure product is manufactured in strict conformity to the Certified Design*
 - *keep records of customer complaints and associated actions taken and make these records available upon request*
 - *Advise AGA of any matters that may affect compliance / certification*
 - *Advise the ACCC, relevant gas Safety Regulators and AGA of any public safety matters (including potential safety matters) / incidents / accidents*

Authorised by Jim Burns
 Client Manager
Date 27 Nov 2019

Audit findings for Certificate 6915

Item	Reference	Description of observation(s) / non-conformance(s)	Customer action(s) required	Due date
1	Markings - Packaging	<p>The following markings were not sighted on the container</p> <ul style="list-style-type: none"> *Class type, (Specification shows 'CLASS III - LPG Storage'). *Curing time, (Specification shows 5-10 hours). *Unopened shelf life, (Specification shows 12 months). *Temperature rating, (Specification shows -10 to 150 Degrees C). 	Implement immediate corrective actions and provide evidence of compliance.	11 Dec 2019